



Electrical Permit

Property

Address: 9200 UNIVERSITY CITY BLVD
Subdivision:

Parcel: 04929521 Lot: Block:
Tax Jurisdiction: CHARLOTTE

Project

Project Number: NR0522989
Project Name: 9200 UNIVERSITY CITY C1 UPFITS
Property Use: Residential - Apartments
USDC: 437 - Commercial - No plan review (small CTAC projects)

Building Type: Existing Bldg
Equipment Type: New

Contact Details

Owner Haven Campus Communities
Phone:
Address: 3284 Northside Parkway, Suite 500
Atlanta, GA 30327

Contractor ADVANTAGE ENTERPRISES SERVIC
Contractor ID: X53569 Home Owner: No
Phone:
License #: 32111
Address: 11523 BECKY CIRCLE
TAMPA, FL 33637

Fees

Permit Fee:	\$59.70	Fax Fee:	\$0.00	Fire Damage Fee:	\$0.00
Triple Fee:	\$0.00	Fee Adjustment:	\$0.00	Commercial Surcharge Fee:	\$0.00
Charge To Account:	Y	Paper Application Fee:	\$0.00	Plans Conversion Fee:	\$0.00
		HFR Fee:	\$0.00	Total Fee:	\$59.70

Permit Fee Calculation is based upon the following costs:

Construction Cost:	\$200.00
Total Equipment Fee:	\$0.00
Total Cost:	\$200.00

Equipment Summary

Equipment Cost (over \$500K):	\$0.00
Equipment Cost at 100%:	\$0.00
Equipment Cost at 20%:	\$0.00

Miscellaneous

Entry Date: 08/22/2018 09:48 pm
Issue Date: 8/23/2018
Utility Company: DUKE ENERGY
Ready for Inspection: N

Entered By: ADVANTAGE ENTERPRISES SERVIC
Issued By: Caulder, Mary
Equipment Changeout: No
Equipment Installation Existing Structure: Yes

Lien Agent

Agent: Chicago Title Company, LLC
Phone: (888) 690-7384
Fax: (919) 489-5231
Email: support@liensnc.com

*This permit will expire if work either has not started within 6 months or is discontinued for a period of 12 months.
No credit or refund will be given unless applied for within 120 days after a permit has expired.*



Electrical Permit

Mailing Address: 19 W Hargett ST Unit: 507, Raleigh, North Carolina 27601
Physical Address: 19 W Hargett ST Unit: 507, Raleigh, North Carolina 27601

Items Installed

Description	Quantity	Description	Quantity	Description	Quantity
Central AC	7	Clothes Dryer	7	Feeder, Conn.(Total Amps)	1600
Fixtures	136	Heat Pump Unit	7	Range	7
Service (Total Amps)	1600	Water Heater	7		

Agency Holds

As of the time of this permit issuance, the following holds exist on this project:

Agency	Phone Number	Hold Reason
Commercial Zoning	7043366692	Plan Review Checklist
Additional Information:		
City Fire	7043362101	Plan Review Checklist
Additional Information:		
CLT Water Backflow	7043915188	Plan Review Checklist
Additional Information:		



Electrical Permit

Agency Holds

As of the time of this permit issuance, the following holds exist on this project:

Agency	Phone Number	Hold Reason
EHS Facility/Lodging	No Phone #	Plan Review Checklist
Additional Information:		
City Engineering	7043366692	Plan Review Checklist
Additional Information: City Engineering Hold		
Urban Forestry	7043366692	Plan Review Checklist
Additional Information: Urban Forestry Hold		

Remarks

Electrical permit needed per Electrical Inspector due to units 4010,4012,3010,3012,2010,1010,1012 in C1 building being fed power from 1600amp Service Switch in meter center MC-3 in C2 building.



Electrical Permit

Inspection Team

Your project has been assigned to the Mega Inspection Team.

Your assigned Project Manager: Herring, Andy

The Mega Team management also includes the following Inspection Supervisors:

Building Supervisor: Moore, Eric W

Electrical Supervisor: Rains, David

Mechanical Supervisor:

Plumbing Supervisor:

To contact your project manager, inspection supervisor or obtain inspection assistance with your project, call 980-314-3134.